



WWW.GROUP-UPC.COM

AACC 2100 - Dewpoint Controller Operator's Guide

COPYRIGHT © 1999
MARATHON MONITORS INC.



AFFILIATED MEMBERS

Furnace Control Corp.

Marathon Monitors Inc.

Process-Electronic

Waukee Engineering Co.

Marathon Monitors Inc.

Part # F200055

COPYRIGHT © 1999
MARATHON MONITORS INC.

No part of this document may be stored or reproduced by any means whatsoever without prior written permission of Marathon Monitors Inc.

All trademarks used in this publication are duly marked and the sole property of their respective owners. No attempt at trademark or copyright infringement is intended or implied.

Marathon Monitors makes no warranties express or implied beyond the written warranty presented at initial purchase. Marathon Monitors Inc. is not responsible for any product, process, damage or injury incurred while using this equipment. Marathon Monitors makes no representations or warranties with respect to the contents hereof and specifically disclaims any warranties of merchantability or fitness for any particular application or purpose.

For assistance please contact:

Marathon Monitors Inc.
TEL: +1 513 772 1000 • FAX: +1 513 326 7090
Toll-Free North America +1-800-547-1055
erika.leeds@group-upc.com
www.group-upc.com

Marathon Monitors Inc.

TABLE OF CONTENTS

Introduction.....	4
Features.....	4
Wiring.....	5
Operation	7
Key Description.....	7
Auto/Man.....	7
Setpoint.....	7
Probe Care	7
Communications Address.....	8
Alarm Setpoints	8
Alarm Display.....	8
Alarm Acknowledge.....	8
Instrument Configuration.....	9
Temperature Units	9
Thermocouple Type.....	10
Communications.....	10
Analog Output	10
Analog Output 2	11
Other Parameters.....	11
Factory Parameter Setups	12

AACC 2100 Preferred Dewpoint Controller

F911581-DAAC

INTRODUCTION

The purpose of this document is to provide a quick reference guide for the AACC 2100 preferred. The preferred version is configured for the most common applications of the dewpoint controller. This document explains the simple steps needed to wire and operate the controller. Also the most common configuration changes are explained.

FEATURES

The AACC 2100 preferred is pre-configured with two control contacts for gas and air solenoids and a 4 to 20 ma analog output for gas control.

A 4-20 ma analog output for retransmission of 0 to 100 deg F dewpoint.

Three alarm contacts are pre-configured for dewpoint deviation (+/-5 deg F), 1400 deg F minimum temperature, and sensor break/probe fault. The contacts are normally closed when there is no alarm condition.

Probe maintenance features are preset for typical applications.

Marathon Monitors Inc.

The RS-485 port is preset for MSI communications at 1200 baud.

WIRING

Refer to the main AACC 2100 manual for EMC and safety requirements when wiring to the instrument. Figure 1 shows the terminal assignments as setup by the factory.

Connect the probe thermocouple to the V+ and V- terminals using the proper extension wire. The thermocouple type preset for the AACC 2100 is type S.

Connect the probe millivolts to terminals 6C (+) and 6B (-). Do not remove the wires that are already on the instrument for the probe impedance test. These wires connect terminals 5D to 6C, terminals 6D to JE, and terminals 5C to JD.

Wire the alarm contacts as desired.

Connect the control outputs for the appropriate devices.

Connect the 4 - 20 ma dewpoint retransmission signal from terminals 3A (+) and 3B (-) to the recording device.

Connect the burn-off contact to the burn-off solenoid.

Connect AC power, 100 -240 VAC, to the live, neutral and ground terminals.

Marathon Monitors Inc.




Figure 1 Signal Assignments

OPERATION

KEY DESCRIPTION

The four rectangular buttons at the bottom of the instrument are used to view or enter data into the instrument. The left most button with a picture of a sheet of paper with the corner bent over is the page key. The next button with the circular arrow is the scroll key. The third button with a triangle pointing down is the down arrow key. the fourth or right most button with the triangle pointing up is the up arrow key.

There are two small round buttons just above the rectangular buttons. The left one is the auto/man button and the right one is the probe care button.

AUTO/MAN

To switch the controller from automatic (auto) to manual (man) or manual to automatic, press the auto/man button until the appropriate beacon is lit.

SETPOINT

When the controller is in auto mode the setpoint can be changed by depressing the up or down arrow keys until the lower display shows the desired value.

PROBE CARE

A probe care cycle can be started by pressing the run/hold button. This will run a probe impedance test followed by a probe burn-off. To start just an impedance test or just a burn-off, press the page key until the Care List is displayed, then press the scroll key once. Then use the arrow keys to select imp for impedance test or burn for burn-off.

Marathon Monitors Inc.

COMMUNICATIONS ADDRESS

The AACC 2100 is preset for MSI communications at 1200 baud. To set the instrument address, press the page key until CMS List is displayed. Press the scroll key once and then use the arrow keys to set the desired address.

ALARM SETPOINTS

Alarm setpoints can be changed from the alarm list. Press the page key several times until AL List is displayed. Press the scroll key until 1dEv or 3FL.1 is displayed. The 1dEv is the process deviation alarm setpoint and the 3FL.1 is the minimum temperature alarm setpoint. The setpoints are changed by using the arrow keys.

ALARM DISPLAY

A sensor break alarm is displayed by a flashing S.br in the upper display. This indicates that the probe thermocouple connection is open. The process deviation alarm (1dEv), minimum temperature alarm (3FL.1), and probe fault (PFLt) alarms show up flashing in the lower display.

ALARM ACKNOWLEDGE

The sensor break, process deviation alarm (1dEv), and the minimum temperature alarm (3FL.1) can not be acknowledged. They will clear by themselves when the alarm condition goes away. The probe fault, PFLt, alarm is acknowledged by pressing the page and scroll keys together.

Marathon Monitors Inc.

INSTRUMENT CONFIGURATION

Configuration mode is used to change items that are usually set once for a specific application. When the instrument is in configuration mode, all contacts open and the analog outputs go to zero.

To enter configuration mode, press the page key several times until ACCS List appears. Press the scroll key once and then use the arrow keys to set the level 1 (access) password. Press the scroll key once and then use the arrow keys to select conF. Press the scroll key once and then use the arrow keys to enter the level 2 (conf) password. Press the scroll key once and the instrument is now in configuration mode.

To exit configuration mode, press the page key several times until exit appears in the upper display. Press the up arrow key once to show yes in the lower display. The instrument will reset, perform its power up sequence, and then enter the normal operating mode.

The items below will give a list name (i.e. inst ConF) and a header for the parameter to be changed. To change the parameter, enter configuration and then press the page key until the list name is displayed. Press the scroll key until the upper display shows the parameter header. Use the arrow keys to select the desired parameter value. When finished, either exit configuration mode or continue to another parameter.

TEMPERATURE UNITS

The temperature unit are under the PV ConF list as parameter unit. Choices are deg C, deg F, deg K or none.

THERMOCOUPLE TYPE

The thermocouple type is under the iP Conf list as parameter inPt. There are many choices but the most common would be S.tc, r.tc, k.tc, or b.tc for type S, R, K, or B thermocouples respectively.

COMMUNICATIONS

Communications setups are under the HA ConF list. The most common parameter to change is the bAud parameter which sets the communications baud rate. Choices are 1200, 2400, 4800, 9600, and 19.20 (k). To select Modbus communications mode, change the Func parameter to mod, the prty parameter to none, the rES parameter to FuLL, and dELy to yes. For Marathon Monitors block mode set the Func parameter to mAr, the prty parameter to EvEn, and dELy to no.

ANALOG OUTPUT 1

Setup parameters for analog output 1 are under the 2A ConF list. The standard setups are the Func parameter is OP.1, the VAL.L parameter is 0, the VAL.H parameter is 100, the unit parameter is mA, the Out.L parameter is 4.0, and the Out.H parameter is 20.0. Therefore, the output provides a 4-20 ma signal for controlling enriching gas. To change the output for dilution air, then set the Func parameter to OP.2. To use the analog output to handle both dilution air and enriching gas, set the Func parameter to OP and the VAL.L to -100. The output would then produce 4 ma when full (100%) dilution air is requested and 20 ma when full (100%) enriching gas is requested. This analog output could also be used to retransmit temperature (IP.1) or millivolts (IP.2).

ANALOG OUTPUT 2

Setup parameters for analog output 2 are under the 3A ConF list. The standard setups are the Func parameter is PV, the VAL.L parameter is 0, the VAL.H parameter is 100, the unit parameter is mA, the Out.L parameter is 4.0, and the Out.H parameter is 20.0. This analog output could also be used to retransmit temperature (IP.1) or millivolts (IP.2).

OTHER PARAMETERS

Other configuration parameters can be changed in a similar manner. Please refer to the configuration section in the main manual for all the options.

Marathon Monitors Inc.

FACTORY PARAMETER SETUPS

* = instrument set the value

Home list

Process Variable		*
Target Setpoint		0
Auto/Manual Mode	M-a	man
Output power	OP	*
Reference Number	rEF	0

Probe List

Process Factor	PF	150
Milivolt Offset	OFFS	0
H-CO Compensation	H-CO	40
Probe Temperature	Ptc	*
Probe Millivolts	Pmv	*
Auxilliary Input	Axin	* (hide)

Care List

Care	CArE	OFF
Measured Recovery Time	prt.r	*
Temperature Minimum	tmin	OFF
Probe Test Interval	Pti	OFF
Maximum Impedance	imPH	20
Probe Test Recovery Time	Ptrt	30
Burn Off Time	bot	60
Burn Off Recovery Time	bort	30
Final Delay	FdE	5
Impedence Result	Imp.r	*

User List

Hide

Number 1	n1	0
Number 2	n2	0
Number 3	n3	0

Marathon Monitors Inc.

Number 4	n4	0
Number 5	n5	0
Number 6	n6	0
Number 7	n7	0
Number 8	n8	0
Number 9	n9	0
Number 10	n10	0
Number 11	n11	0
Number 12	n12	0
Number 13	n13	0
Number 14	n14	0
Number 15	n15	0

Alarm List

Alarm 1 Setpoint	1---	5
Alarm 3 Setpoint	3---	1400
Alarm 1 Hysteresis	HY1	1 (hide)
Alarm 2 Hysteresis	HY2	na (hide)
Alarm 3 Hysteresis	HY3	1 (hide)
Loop Break Time	Lbt	OFF (hide)
Enable Diagnostic Messages	diAG	NO (hide)

Autotune List

Autotune Enable	tunE	OFF
Automatic manual Reset Calculation	Adc	MAN

PID List

Current PID Set	Set	Pid.1
Proportional Band PID1	Pb	1
Intergal Time PID1	ti	OFF
Derivative Time PID1	td	OFF
Manual Reset	rES	0
Cutback High	Hcb	Auto (hide)
Cutback Low PID1	Lcb	Auto (hide)

Marathon Monitors Inc.

Relative cool gain set 1	rELC	1 (hide)
Proportional Band PID2	Pb2	1
Intergal Time PID2	ti2	OFF
Derivative Time PID2	td2	OFF
Manual Reset PID2	rES2	0
Cutback High PID2	Hcb2	Auto (hide)
Cutback Low PID2	Lcb2	Auto (hide)
Relative cool gain set 2	rEL.2	1 (hide)

Setpoint List

Setpoint Select	SSEL	SP 1
Setpoint 1	SP1	0
Setpoint 2	Sp2	0
Setpoint Low Limit	SPL	-100 (hide)
Setpoint High Limit	SPH	212 (hide)
Setpoint 2 Low Limit	SP2.L	-100 (hide)
Setpoint 2 High Limit	SP2.H	212 (hide)
Setpoint Rate Limit	Sprr	OFF (hide)
Holdback Type	Hb.tY	OFF (hide)

Input List

Filter 1	FiLt	OFF
Filter 3	FLT3	OFF
Simple offset 1	OFS.1	0
ADC millivolts 1	mv.1	*
ADC millivolts 2	mv.2	*
CJC Temperature	CJC.1	*
IP1 linearized value	Li.1	*
IP3 linearized value	Li.3	*
Current input used for pv	PV.SL	*

Output List

Low Power Limit	OP.Lo	-100
High Power Limit	OP.Hi	100

Marathon Monitors Inc.

Output Rate Limit	Oprr	OFF
Cycle time OP1	CYC.1	10
OP1 Minimum On Time	ont.1	Auto
Cycle time OP2	CYC.2	10
OP2 Minimum On time	ont.2	Auto
Deadband	db	OFF
Sensor Break Output Power	Sb.OP	0
Comms List		
Comms Address	Addr	1
Info List		Hide
Inst Conf		
Function: O2, %C, Dewpoint, Redox	Zr.Fn	dw.P
Control Type	Ctrl	Pid
Instrument type: Monitor/Controller	tYPE	Ctrl
Control Action	Act	DIR
Type of cooling	COOL	lin
Control Time Units	ti.td	Sec
dtYP	dtYP	PV
Manual Key Enable	m-A	EnAb
Run hold button	r-h	EnAb
Power feedback	PwrF	OFF
Feedforward Type	Fwd.t	nonE
Sensor Break Action	Sbr.t	Sb.OP
Forced manual output	FOP	no
BCD Input Function	bcd	nonE
Gain Scheduling	Gsch	no
PV Conf		
Instrument Units	unit	F

Marathon Monitors Inc.

Display Resolution	dEc.P	nnnn
Range low	rnG.L	-100
Range High	rnG.H	212
IP Conf		
Linearisation type	inPt	S.tc
CJC Type	CJC	Auto
Sensor break Impedance	imP	Auto
SP Conf		
Number of Setpoints	nSP	2
Remote Tracking Configuration	rm.tr	OFF
manual track Configuration	m.tr	OFF
SRL rate units	rmP.U	PSEC
Remote Setpoint Configuration	rmt	nonE
Alarm Conf		
Alarm 1 Type	AL1	dEv
Alarm 1 Latch	Ltch	NO
Alarm 1 Block	bLoc	NO
Alarm 2 Type	AL2	OFF
Alarm 2 Latch	Ltch	NO
Alarm 2 Block	bLoc	NO
Alarm 3 Type	AL3	FL.1
Alarm 3 Latch	Ltch	NO
Alarm 3 Block	bLoc	NO
Alarm 4 Type	AL4	OFF
Alarm 4 Latch	Ltch	NO
Alarm 4 Block	bLoc	NO
LA Conf		
Logic Input A Ident	id	LoG.I
Logic Input A Slot Function	Func	CArE

Marathon Monitors Inc.

LB Conf

Logic Input B Ident	id	LoG.I
Logic Input B Slot Function	Func	burn

AA Conf

Fixed Module AA Ident	id	rELy
Fixed Module AA Slot Function	Func	dIG
Summary OP AA invert	Sens	inv
Summary OP AA Conf		1dEv

Module HA Conf

Interface Module H Ident	id	cmS
Interface Module H Slot Function	Func	mAr
Baud Rate	bAud	1200
Comms Parity	Prty	EvEn
Comms Delay	dELY	no

Module JA Conf

Logic Input B Ident	id	nonE
Logic Input B Slot Function	Func	nonE

Module 1A Conf

Module 1A Ident	id	rELy
Module 1A Slot Function	Func	OP.1
Module 1A Low Value	VAL.L	0
Module 1A High Value	VAL.H	100
Module 1A Low Output Range	Out.L	0
Module 1A High Output Range	Out.H	100

Module 1C Conf

Module 1C Ident	id	rELy
-----------------	----	------

Marathon Monitors Inc.

Module 1C Slot Function	Func	OP.2
Module 1C Low Value	VAL.L	0
Module 1C High Value	VAL.H	100
Module 1C Low Output Range	Out.L	0
Module 1C High Output Range	Out.H	100

Module 2A Conf

Module 2A Ident	id	dc.rE
Module 2A Slot Function	Func	OP.1
Module 2A Low Value	VAL.L	0
Module 2A High Value	VAL.H	100
Output 2A units	unit	mA
Module 2A Low Output Range	Out.L	4
Module 2A High Output Range	Out.H	20

Module 3A Conf

Module 3A Ident	id	dc.rE
Module 3A Slot Function	Func	PV
Module 3A Low Value	VAL.L	0
Module 3A High Value	VAL.H	100
Output 3A units	unit	mA
Module 3A Low Output Range	Out.L	4
Module 3A High Output Range	Out.H	20

Module 4A Conf

Module 4A Ident	id	rELy
Module 4A Slot Function	Func	dIG
Summary OP 4A Invert	SEnS	inv
Summary OP 4A configuration		3FL.1

Marathon Monitors Inc.

Module 4C Conf

Module 4C Ident	id	rELy
Module 4C Slot Function	Func	dIG
Summary OP 4C Invert	SEnS	inv
Summary OP 4C configuration		Sbr/PFLt/VF Lt

Module 5A Conf

Module 5A Ident	id	rELy
Module 5A Slot Function	Func	dIG
Summary OP 5A Invert	SEnS	nor
Summary OP 5A configuration		burn/Veri

Module 5C Conf

Module 5C Ident	id	rELy
Module 5C Slot Function	Func	dIG
Summary OP 5C Invert	SEnS	nor
Summary OP 5C configuration		ImP

Module 6A Conf

Module 6A Ident	id	dC.iP
Module 6A Slot Function	Func	PmV
Module 6A Input Type	inPt	Hiln
Module 6A Input Value Low	inP.L	-0.2
Module 6A Input Value High	inP.H	1.8
Module 6A Displayed Value Low	VAL.L	-200
Module 6A Displayed Value High	VAL.H	1800

CAL Conf

Calibration point	rcAL	nonE
User calibration enable	VCAL	no

Marathon Monitors Inc.

Low point for Input 1	Pt1.L	0
High point for Input 1	Pt1.H	0
Offset low for input 1	OF1.L	0
Offset high for input 1	OF1.H	0

PASS Conf

Access Mode User Password	ACC.P	1
Configuration Mode User Password	cnF.P	2

Marathon Monitors Inc.

INDEX

A

ALARM ACKNOWLEDGE, 7
ALARM DISPLAY, 7
ALARM SETPOINTS, 7
ANALOG OUTPUT 1, 9
ANALOG OUTPUT 2, 10
AUTO/MAN, 6

K

KEY DESCRIPTION, 6

O
OPERATION, 6
OTHER PARAMETERS, 10

C

COMMUNICATIONS, 9
COMMUNICATIONS ADDRESS, 7

P

PROBE CARE, 6

F

FACTORY PARAMETER SETUPs,
11
FEATURES, 3

S

SETPOINT, 6

I

INSTRUMENT CONFIGURATION, 8
INTRODUCTION, 3

T

TEMPERATURE UNITS, 8
THERMOCOUPLE TYPE, 9

W

WIRING, 4